

RESPONSE TO BIDDERS' QUESTIONS

Contract: 2025 Roof Replacement Project PRC# 2025004654

Owner: Town of Lansing

Date: August 11, 2025

ENGINEER: T. G. Miller, P.C.
605 West State Street, Suite A
Ithaca, New York 14850
(607) 272-6477 (607) 273-6322 (fax)
dmh@tgmillerpc.com

Below is a response to bidders' questions:

1. Question: When adding additional rafters alongside the existing rafters for the School House, does the rafter tail need to extend all the way to the fascia board or can the rafter be cut short to set on the beam?

Response: The additional rafters do not need to extend to the facial board. The rafters can be scribed and set on top of the existing beam to allow the transfer of load from the rafter to the beam. The beam will not require mortising to accept the rafter.

END OF SECTION